

DOUBLE STRAINERS CLEANING Safe Operating Procedure Updated April 14, 2022

Page 1 of 1

Hazards	oil spill
Tools/Equipment	spill cleanup containment material, wrenches
Employee Group(s)	Facilities Management – Central Heating Plant

Required PPE:







Safety Shoes

Eye Protection

Gloves

SAFE WORK PRACTICES

- Do not perform the procedure or operate the equipment until you have been appropriately trained and authorized to do so by your supervisor.
- Inspect required personal protective equipment (PPE) and replace if required.

PROCEDURE

- 1. Switch strainer from one side to the other.
- 2. Check for leaks in the strainer that is now in service.
- 3. Unbolt basket cap and remove.
- 4. Remove basket.
- 5. Clean basket and replace.
- 6. Fill strainer with diesel or proper fluid.
- 7. Bolt basket cap back in place.
- 8. Leave strainer out of service.